


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 324Dated: 10/03/2025

It is certified that an inspection team headed by Mr. Vinay Pratap Singh Thakur (S.D.O.)
 (Name of Officers with designation) from P.H.E Sub. Division Sihora

PHED inspected the **MERIDIAN INTERNATIONAL SCHOOL, NH-30, RAI SIMARIYA ROAD, SIHORA, DIST. JABALPUR, MP** on 07/03/2025 and on the basis of Water Test Report (Attached) bearing no. Report no. 195 dated 10/02/2025 of P.H.E.D Lab Sub. Division, Sihora (PHED Lab) certified that the **MERIDIAN INTERNATIONAL SCHOOL, NH-30, RAI SIMARIYA ROAD, SIHORA, DIST. JABALPUR, MP** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1 year


 Assistant Engineer
 P.H.E. Sub Division
 Sihora

Signature with seal

:- Vinay Pratap Singh Thakur

Name

:- S.D.O.


Designation

Name & address of the office/Department: - P.H.E Sub Division Sihora

To,

MERIDIAN INTERNATIONAL SCHOOL,
NH-30, RAI SIMARIYA ROAD, SIHORA, DIST. JABALPUR, MP
 (Name and address of the institution)


Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies


 संचय
 श्री प्रभात श्री प्रताप शिक्षा समिति
 बुढागर, गाँधीग्राम सिहोरा जि. जबलपुर


 Principal
Meridian International School
 Sihora

SUB DIVISION WATER TESTING LABORATORY
Office of the Assistant Engineer, Public Health Engg. Sub Division Sihora Distt. Jabalpur (M.P.)

WATER TESTING REPORT

Report no - 195	Date,	10/3/2025	District.....Jabalpur (code no -00/0		
Ref. NO - nil/07.03.2025	Date,	7/3/2025	Village & Location		Block
To, O/O THE MERIDIAN SCHOOL RAI SIMARIYA ROAD SIHORA DISTT. - JABALPUR			1- MERIDIAN INTERNATIONAL SCHOOL NH-30 RAI SIMARIYA ROAD SIHORA DISTT. - JABALPUR ((TUBEWELL WTER)		SIHORA
Sample Collected by	A.E.PHED SIHORA				
Date of collection	7/3/2025				
Source	BOREWELL				
Date of receipt	7/3/2025				
Date of Testing	10/3/2025				
Test conducted by	Lab Staff				
<i>Drinking Water Specifications As per BIS 10500:2021 (Second Revision)</i>					
Sl no.	Characteristic	Unit	Acceptable	Cause for rejection	RESULT
PHYSICAL-TEST					
1	Turbidity	NTU	1.0	5.0	2.3
2	Colour	Pt. Cobalt			NIL
3	Test & Odour	Unobjectionable	Unobjectionable		Unobjectionable
CHEMICAL-TEST					
4	pH	...	6.5 to 8.5	6.5 to 8.5	7.94
5	Conductivity	µMhos/cm	518
6	Alkalinity	mg/l	200	600	150
7	Chloride (As Cl)	mg/l	250	1000	35.0
8	Nitrates	mg/l	45	45	23.52
9	Total Hardness (As CaCO ₃)	mg/l	200	600	220
10	Calcium (As Ca)	mg/l	75	200	44
11	Magnesium (As Mg)	mg/l	30	100	26.78
12	Total dissolved solid	mg/l	500	2000	318
13	Iron (As Fe)	mg/l	0.30	1.0	0.30
14	Manganese (As Mn)	mg/l	0.10	0.30	-
15	Fluoride (As F)	mg/l	1.00	1.50	0.0
16	Sulphates As SO ₄	mg/l	200	400	0.73
17	Residual Chlorine	mg/l	0.20	1.0	-
BACTERIOLOGICAL-TEST					
18	Total Coliform	100ml	0	..	0
19	E Coli or Thermo tolerant coliforms	100ml	0	..	0
REMARK:-					
Note:- 1. As above result compared with BIS 10500:2021					
2. Samples are not collected by us.					
3. Not to be produced at court of law.					
 Assistant Engineer P.H.E. Sub Division Sihora			 CHEMIST Public Health Engg. Sub Division Sihora (M.P.)		


सचिव
श्री प्रभात श्री प्रताप शिक्षा समिति
बुद्धगढ़, गांधीग्राम सिहोरा जि. जबलपुर


Principal
Meridian International School
Sihora